



Faisalabad Electric Supply Company Limited

CANAL ROAD, ABDULLAHPUR, FAISALABAD

Tel # 041-9230006

Tel # 041-9230007

OFFICE OF THE
CHIEF EXECUTIVE OFFICER
FESCO (WAPDA) FAISALABAD

Dated **30-01-2024**

NO. 4711 /T&G-2

S.E GSO Circle

FESCO Faisalabad.

Subject:- APPROVAL OF SHUT DOWN SCHEDULE 02/2024 AREA EFFECTED NIL (ALTERNATE SOURCE).

As desired S.E GSO Circle FESCO Faisalabad vides his letter No. **1028-30** dated **29-01-2024** the following shut downs are approved as under:-

SR. NO	NAME OF G/S / T/Line (EQUIPMENT)	DATE	TIME			PURPOSE	AREA AFFECTED.
			FROM (HRS)	TO (HRS)	DUR: (HRS)		
1	132KV Transmission Jhang City - Jhang-II controlling 132KV Circuit Breakers (JHG-3 , JAG-2)	01-02-24	10:00	14:30	4:30	For cleaning/replacement of disc insulator T.No 06-11	Supply will be restored from alternative source (132KV Khewa).
2	132KV T/Line Pirmahal - 220KV T.T.Singh Controlling 132KV Circuit Breakers (PMH-1 , E8Q1)	01-02-24	9:30	14:00	4:30	To setright the jumpers at Tower No. 42,43.	Supply will be restored from alternative source (132KV Shor Kot Road).
3	132KV Transmission Jhang-II - Khewa controlling 132KV Circuit Breakers (JAG-1 , ISO 101)	06-02-24	10:00	14:30	4:30	For cleaning/replacement of disc insulator T.No 01-05	Supply will be restored from alternative source (132KV Jhang City).
4	132KV Transmission Factory Area - Faisalabad City (GIS) controlling 132KV Circuit Breakers (FFA-2 , FBC-2)	06-02-24	9:00	14:30	5:30	For cleaning/replacement of disc insulator T.No 01-15	Supply will be restored from alternative source (132KV Jhang Road).
5	132KV T/Line Pirmahal - 220KV T.T.Singh Controlling 132KV Circuit Breakers (PMH-1 , E8Q1)	06-02-24	9:30	14:00	4:30	To setright the jumpers at Tower No. 84,85.	Supply will be restored from alternative source (132KV Shor Kot Road).
6	132 KV Grid Station Bhera Industrial 132KV Circuit Breaker BRI-1 Controlled by 132KV T/Line Bhera Industrial--Head Faqirian (BRI1,HFQ2)	06-02-24	09:00	12:00	3:00	Annual Maintenance of 132KV Circuit Breaker BRI-1,	NIL Supply will be Restored from Alternative Source 220KV G/S New Ludewala
7	132KV Transmission Line Millat Road - Nishatabad Controlled by 132KV Circuit Breaker (MLR-1 , E4Q1).	07-02-24	09:00	14:00	5:00	To set right the jumper Blue phase at T.No275.	Nil Supply will be restored through alternative source i.e 132KV C.B MLR-2.
8	132KV G/S Narwala Road. 132KV Circuit Breaker NWR-4 controlling 132KV Transmission Line Narwala Road - 500KV Fsd west	07-02-24	9:00	14:00	5:00	For annual maintenance of Circuit Breaker and replacement of deteriorated Line Isulator & C.T clamps	Supply will be restored from alternative source (220KV Samundri Road).
9	132KV T/Line Toba Tek Singh - Shorkot City Controlling 132KV Circuit Breakers (TTS-4 , SRC-3)	07-02-24	9:30	14:00	4:30	To setright the jumpers at Tower No. 23-24.	Supply will be restored from alternative source (132KV Shor Kot Road).
10	132KV Transmission Samundri - Faisalabad City (GIS) controlling 132KV Circuit Breakers (SRD-12 , FBC-1)	07-02-24	9:00	14:30	5:30	For cleaning/replacement of disc insulator T.No 01-05	Supply will be restored from alternative source (132KV Factory Area).
11	132KV T/L Mianwali-Wan Bhachran cont:132KV CB (MNW-1,WBC-2) at 132KV G/S Mianwali	07-02-24	9:00	14:00	5:00	Replacment of broken disc insulator at loc no.123 and tightening of jumper at loc no.188	Supply will be restored through alternate source MNW-2

12	132KV T/L Wan Bhachran-Piplan cont:132KV CB (WBC-5, PPL-2) at 132KV G/S Wan Bhachran	07-02-24	9:00	14:00	5:00	Washing and cleaning of polluted disc insulator at loc no 32.38.	Supply will be restored through alternate source PPL-1
13	132KV T/L Piplan-Darya Khan cont:132KV CB (PPL-6,DYK-2)at 132KV G/S Piplan	08-02-24	9:00	15:00	6:00	Tightening and of jumpers at loc no.71.83.96	Supply will be restored through alternating source DYK-1
14	132KV Transmission H.B. Shah - 220KV T.T Singh controlling 132KV Circuit Breakers (HBS-5 , E4Q1)	12-02-24	10:00	15:00	5:00	For cleaning/replacement of disc insulator T.No 27-38	Supply will be restored from alternative source (220KV T.T. Singh).
15	132KV Transmission Gojra - Samundri City controlling 132KV Circuit Breakers (GRA-1 , SMD-1)	12-02-24	9:00	14:30	5:30	For cleaning/replacement of disc insulator T.No 130,196,122,123	Supply will be restored from alternative source (220KV Samunri Road).
16	132 KV Grid Station Bhera Industrial 132KV Circuit Breaker BRI-2 Controlled by 132KV T/Line 220KV New Ludewala---Bhera Industrial (E11Q1,BRI2)	12-02-24	09:00	12:00	3:00	Annual Maintenance of 132KV Circuit Breaker BRI-2,	NIL Supply will be Restored from Alternative Source 132KV G/S Head Faqirian
17	66 KV T/Line Ludewala--- Mitha Tiwana Controlled by 66 KV Circuit Breaker (LWA11, ISO101)	12-02-24	0930	1400	4:30	For Replace the Damage Jumper at Tower No. 142	NIL Supply will be restored from alternative source through 132 KV G/S Quidabad
18	132 KV T/Line Sargodha-II--- 132KV Chak 126 SB Controlled by 132 KV Circuit Breaker (SGA3---CSB2)	12-02-24	09:30	13:30	4:00	Cleaning, Washing Disc Insulators & Tightening the Jumpers from tower No. 30-60	NIL Supply will be restored from alternative source through 220 KV G/Station Lalian
19	132 Kv T/Line 220KV New Ludewala---Bhera Industrial Controlled by 132 Kv Circuit Breaker E11Q1---BRI2	12-02-24	09:30	15:00	5:30	Disk Cleaning and jumper Tightening of tower No. 01-36	NIL Supply will be restored from alternative source through 132 kv G/S Head Faqirian
20	132KV T/L Piplan -L B Chashma cont:132KV CB (PPL-1, CHM-2)at 132KV G/S Piplan	12-02-24	9:00	14:00	5:00	Replacement of Disc Insulator with anti fog disc insulator at loc no.32.33	Supply will be restored through alternating source CHM-1
21	132KV Transmission Nia Lahore - 500KV Fsd west controlling 132KV Circuit Breakers (NLH-2 , E13Q1)	13-02-24	9:00	14:30	5:30	For cleaning/replacement of disc insulator T.No 48-70	Supply will be restored from alternative source (220KV Samunri Road).
22	132KV T/Line Toba Tek Singh - Shorkot City Controlling 132KV Circuit Breakers (TTS-4 , SRC-3)	13-02-24	9:30	14:00	4:30	To setright the jumpers at Tower No. 153,154	Supply will be restored from alternative source (132KV Shor Kot Road).
23	132 KV Grid Station Sargodha-II 132KV Circuit Breaker SGA-4 Controlled by 132KV T/Line Ludewala---Sargodha-II (LWA1,SGA4)	13-02-24	09:00	12:00	3:00	Annual Maintenance of 132KV Circuit Breaker SGA-4,	NIL Supply will be Restored from Alternative Source 132KV G/S Chak 126 S.B
24	132 KV T/Line 220KV New Ludewala---Sardar Pur Noon Controlled by 132 KV Circuit Breaker (E12Q1--ISO102)	13-02-24	09:30	15:00	5:30	Disk Cleaning and jumper Tightening of tower No.27-50	NIL Supply will be restored from alternative source through 132 KV G/S Bhalwal
25	132 KV T/L Daud Khel-Shehbaz Khel cont: 132 KV (DKL-4,SBK-1)at 132KV G/S Daud Khel	13-02-24	9:00	15:00	6:00	Repair the damage conductor b/w loc no.1-2Tightening of jumpers at loc no,3.	Supply will be restored through alternate source SBK-2

26	132 KV T/L Behal-Fateh Pur cont ;132 KV CB (BHL-2,FPR-2) at 132 kv Behal	13-02-24	9:00	14:00	5:00	Tightening of jumpers at loc no. 76.83.87	Supply will be restored through alternating source BHL-1
27	132KV Transmission Jhang City - Jhang-II controlling 132KV Circuit Breakers (JHG-3 , JAG-2)	14-02-24	10:00	15:00	5:00	For cleaning/replacement of disc insulator T.No 02-05	Supply will be restored from alternative source (132KV Khewa).
28	132KV T/Line Toba Tek Singh - 220KV T.T.Singh Controlling 132KV Circuit Breakers (TTS-5 , E6Q1)	14-02-24	9:30	13:00	3:30	To setright the jumpers at Tower No. 1-10	Supply will be restored from alternative source (132KV Shor Kot City).
29	132 KV T/Line 220KV New Ludewala---132KV Jauharabad Controlled by 132 KV Circuit Breaker (E5Q1,JRB1)	14-02-24	09:30	15:00	5:30	For Repairing the Damage Earth Wire Between Tower No. 232-233	NIL Supply will be restored from alternative source 132 KV G/Station Quaidabad
30	132 KV Grid Station Ludewala 132KV Circuit Breaker LWA-4 Controlled by 132KV T/Line 220KV New Ludewala--- 132 Ludewala (E10Q1,LWA4)	14-02-24	09:00	12:00	3:00	Annual Maintenance of 132KV Circuit Breaker LWA-4,	NIL Supply will be Restored from Alternative Source 220KV G/S New Ludewala
31	132 KV T/Line Kirana---132KV Lalian Controlled by 132 KV Circuit Breaker KNH2---LLN2	14-02-24	09:30	13:30	4:00	Cleaning, Washing Disc Insulators & Tightening the Jumpers from tower No. 01-14	NIL Supply will be restored from alternative source through 220 KV G/Station New Lalian
32	132KV T/L Fazil-AI mooez cont:132KV CB (FZL-2,E1Q1)at 132KV G/S Fazil	14-02-24	9:00	14:00	5:00	Washing and cleaning of polluted disc insulator at loc no 49.50	Supply will be restored through alternating source FZL-1
33	132KV Transmission Line Jhang - H.B. Shah controlling 132KV Circuit Breakers (JHG-4 , HBS-1)	15-02-24	10:00	15:00	5:00	For cleaning/replacement of disc insulator T.No 13-24	Supply will be restored from alternative source (132KV Gojra).
34	132 KV Grid Station Ludewala 132KV Circuit Breaker LWA-2 Controlled by 132KV T/Line Ludewala---Kirana Hill (LWA2,KNH1)	15-02-24	09:00	12:00	3:00	Annual Maintenance of 132KV Circuit Breaker LWA-2,	NIL Supply will be Restored from Alternative Source 132KV G/S Lalian
35	132 KV T/L Daud Khel-Wan Bhachran cont: 132 KV (DKL-3,WBC-1)at 132KV G/S Daud Khel	15-02-24	9:00	15:00	6:00	Repair the damage conductor b/w loc no.10-11	Supply will be restored through alternate source WBC-2
36	66 KV T/L Piplan -Kaloor Kot cont: 66 KV CB (PPL-4, ISO-101) at 132KV G/S Piplan	15-02-24	9:00	14:00	5:00	Tighteningand repair of jumpers at loc no.1.2.3	NOTE Supply of 66 KV G/S Kaloor Kot will be restored from 66 KV CB BKR-4 at 132 kv G/S Bhakhar
37	132KV T/Line Toba Tek Singh - 220KV T.T.Singh Controlling 132KV Circuit Breakers (TTS-5 , E6Q1)	16-02-24	9:00	13:00	4:00	To setright the jumpers at Tower No. 156,161	Supply will be restored from alternative source (132KV Shor Kot City).
38	132KV T/Line H.B. Shah - Athara Hazari Controlling 132KV Circuit Breakers (HBS-3 , ATH-2)	19-02-24	10:00	15:00	5:00	For cleaning/replacement of disc insulator T.No 25-31	Supply will be restored from alternative source (132KV H.B. Shah).
39	132KV T/Line Shorkot Road to Pirmahal Controlling 132KV Circuit Breakers (SKR-2 , PMH-2)	19-02-24	9:30	15:00	5:30	To setright the gound clearance at Tower No. 13-14	Supply will be restored from alternative source (132KV Shor Kot City).

40	132KV T/Line Jauharabad---ABC (CCT-I) Controlled By 132KV Circuit Breaker (JRB3,ABC1)	19-02-24	09:30	15:00	5:30	Cleaning, Washing the Disc Insulator & Tightening the PG Clamps of Dead End Towers from tower No. 51-75	NIL Supply will be restored from alternative source through 132 KV G/S Jauharabad
41	132KV T/L Wan Bhachran - Quaidabad cont: 132KV CB (WBC-4, QDB-1) at 132KV G/S Wan Bhachran	19-02-24	9:00	15:00	6:00	Replacement of Disc Insulator with anti fog disc insulator at loc no.9.10.11	Supply will be restored through alternating source QDB-2
42	132KV G/S Jhang Road. 132KV Circuit Breaker JRD-4 controlling 132KV Transmission Line Jhang Road - Samundri Road	20-02-24	9:00	13:00	4:00	For annual maintenance of Circuit Breaker and replacement of deteriorated Line Insulator & C.T clamps	Supply will be restored from alternative source (500KV Fsd west).
43	132KV T/Line Shorkot Road - Pirmahal Controlling 132KV Circuit Breakers (SKR-2 , PMH-2)	20-02-24	9:30	15:00	5:30	To setright the Jumpers at Tower No. 68,1	Supply will be restored from alternative source (132KV Shor Kot City).
44	132KV T/Line Sargodha-II---Bhagtanwala (CCT-I) Controlled by 132 KV Circuit Breaker (SGA1--BGW1)	20-02-24	09:30	15:00	5:30	Disk Cleaning and jumper Tightening of tower No. 01-36	NIL Supply will be restored from alternative source through 132 KV G/S Sargodha-II
45	132 KV T/Line Lalian---Barana (CCT-I) Controlled by 132 KV Circuit Breaker LLN3---BNA1	20-02-24	09:30	13:30	4:00	Cleaning, Washing the disc insulators from tower no. 50-81	NIL Supply will be restored from alternative source through 132 KV G/Station Lalian
46	132KV T/L Bhakkar-Chheena cont: 132KV CB (BKR-1,CNA-1) at 132KV G/S Bhakkar	20-02-24	9:00	14:00	5:00	Tightening of jumpers at loc no. 1.2.9	Supply will be restored through alternating source CNA-2
47	132KV T/Line Kamalia to Chichawatni Controlling 132KV Circuit Breakers (KML-2 , CCW-5)	21-02-24	9:30	14:00	4:30	To setright the Jumpers at Tower No.1 , 4	Supply will be restored from alternative source (132KV Mureed Wala).
48	132 KV Grid Station Ludewala 132KV Circuit Breaker LWA-6 Controlled by 132KV T/Line 220KV New Ludewala--- 132 Ludewala (E13Q1,LWA6)	21-02-24	09:00	12:00	3:00	Annual Maintenance of 132KV Circuit Breaker LWA-6,	NILSupply will be Restored from Alternative Source 220KV G/S New Ludewala
49	132KV T/Line Jauharabad---ABC (CCT-II) Controlled By 132KV Circuit Breaker (JRB4,ABC2)	21-02-24	09:30	14:00	4:30	Cleaning, Washing the Disc Insulator & Tightening the PG Clamps of Dead End Towers from tower No. 51-75	NIL Supply will be restored from alternative source through 132 KV G/S Jauharabad
50	132KV Transmission Jhang-II - Khewa controlling 132KV Circuit Breakers (JAG-1 , ISO 101)	22-02-24	10:00	15:00	5:00	For cleaning/replacement of disc insulator T.No 06-12	Supply will be restored from alternative source (132KV Jhang City).
51	132KV T/Line Shorkot Road - Shorkot City Controlling 132KV Circuit Breakers (SKR-3 , SRC-2)	22-02-24	9:30	14:30	5:00	For cleaning/washing of disc insulators from Tower No. 1,68	Supply will be restored from alternative source (132KV Pir Mahal).
52	132 KV T/L Behal-Chheena cont ;132 KV CB (BHL-1,CNA-2) at 132 kv Behal	22-02-24	9:00	14:00	5:00	Tightening of jumpers at loc no. 1.2.9	Supply will be restored through alternating source CNA-1
53	132KV T/Line Jhakhar - Kamalia Controlling 132KV Circuit Breakers (JKR-2 , KML-1)	23-02-24	9:30	14:00	4:30	To setright the Jumpers at Tower No.96,97	Supply will be restored from alternative source (132KV Chichawatni).
54	132KV T/Line Shor Kot Road - Pir Mahal Controlling 132KV Circuit Breakers (SKR-2 , PMH-2)	26-02-24	9:30	14:00	4:30	For cleaning/replacement of disc insulator T.No 73-	Supply will be restored from alternative source (132KV Chichawatni).

						76	
55	132 KV Grid Station Ludewala 132KV Circuit Breaker LWA-7 Controlled by 132KV T/Line 220KV New Ludewala--- 132 Ludewala (E14Q1,LWA7)	26-02-24	09:00	12:00	3:00	Annual Maintenance of 132KV Circuit Breaker LWA-7,	NIL Supply will be Restored from Alternative Source 220KV G/S New Ludewala
56	132 KV T/Line Lalian---Barana (CCT-II) Controlled by 132 KV Circuit Breaker LLN4---BNA2	26-02-24	09:30	13:30	4:00	Cleaning, Washing the disc insulators from tower No. 30-45	NIL Supply will be restored from alternative source through 132 KV G/Station Lalian
57	132KV T/Line Jhakhar - Chichawatni Controlling 132KV Circuit Breakers (JKR-1 , CCW-6)	27-02-24	9:30	14:00	4:30	To setright the Jumpers at Tower No.39-41	Supply will be restored from alternative source (132KV Chichawatni).
58	132KV G/S Shor Kot City 132KV Circuit Breaker SRC-1 controlling 132KV Transmission Line Shor Kot City - Head Sidhna	27-02-24	10:30	14:30	4:00	For annual maintenance of 132KV C.B and its allied Eupiment.	Supply will be restored from alternative source (132KV Shor Kot Road).
59	132KV G/S Shor Kot City 132KV Circuit Breaker SRC-2 controlling 132KV Transmission Line Shor Kot City - Shor Kot Road	27-02-24	10:30	14:30	4:00	For annual maintenance of 132KV C.B and its allied Eupiment.	Supply will be restored from alternative source (132KV Pir Mahal).
60	132 KV Grid Station Ludewala 132KV Circuit Breaker LWA-8 (CCT-I) Controlled by 132KV T/Line Ludewala-- Sargodha City (LWA8, SGC1)	27-02-24	09:00	12:00	3:00	Annual Maintenance of 132KV Circuit Breaker LWA-8,	NIL Supply will be Restored from Alternative Source 132KV G/S Ludewala
61	132KV T/Line Sargodha-II--- Bhagtanwala (CCT-II) Controlled by 132 KV Circuit Breaker (SGA2-- BGW2)	27-02-24	09:30	15:00	5:30	Disk Cleaning and jumper Tightening of tower No. 01-36	NILSupply will be restored from alternative source through 132 KV G/S Sargodha-II
62	132KV T/L Bhakkar- Rakh Dagan cont: 132KV CB (BKR-5, RKD-2) at 132KV G/S Bhakkar	27-02-24	10:00	15:00	5:00	Tightening of jumpers and sustaion of clamps 231.233.234	Supply will be restored through alternating source RKD-1
63	132KV T/Line H.B. Shah - Athara Hazari Controlling 132KV Circuit Breakers (HBS-2 , ATH-3)	28-02-24	10:00	15:30	5:30	For cleaning/replacement of disc insulator T.No 24- 28	Supply will be restored from alternative source (132KV H.B. Shah).
64	132KV G/S Pir Mahal. 132KV Circuit Breaker PMH-1 controlling 132KV Transmission Line Pir Mahal - 220KV T.T. Singh.	28-02-24	9:00	13:30	4:30	For annual maintenance of Circuit Breaker.	Supply will be restored from alternative source (132KV Shor Kot Road).
65	132KV T/Line Gojra - 220KV T.T.Singh Controlling 132KV Circuit Breakers (GRA-3 , E12Q1)	28-02-24	9:00	13:00	4:00	For cleaning/washing of disc insulators from Tower No.1,58	Supply will be restored from alternative source (500KV Fsd west).
66	132 KV Grid Station Ludewala 132KV Circuit Breaker LWA-15 Controlled by 132KV Bus Coupler between Busbar No.1 & 2	28-02-24	09:00	12:00	3:00	Annual Maintenance of 132KV Circuit Breaker LWA-15,	NIL
67	132 KV T/Line 132KV Ludewala--- Kirana Hill Controlled by 132 KV Circuit Breaker (LWA2---KNH1)	28-02-24	09:30	13:30	4:00	Cleaning, Washing Disc Insulators from tower No. 20-40	NIL Supply will be restored from alternative source through 132 KV G/Station Lalian
68	132KV T/Line Gojra - 220KV T.T.Singh Controlling 132KV Circuit Breakers (GRA-4 , E13Q1)	29-02-24	9:00	13:00	4:00	For cleaning/washing of disc insulators from Tower No.1,58	Supply will be restored from alternative source (500KV Fsd west).

69	132 KV Grid Station Ludewala 132KV Circuit Breaker LWA-9 (CCT-II) Controlled by 132KV T/Line Ludewala--- Sargodha City (LWA9, SGC2)	29-02-24	09:00	12:00	3:00	Annual Maintenance of 132KV Circuit Breaker LWA-9,	NIL Supply will be Restored from Alternative Source 132KV G/S Ludewala
----	--	----------	-------	-------	------	--	---

It is therefore requested to carryout work within the above mentioned time frame to avoid any inconvenience to the public as well as to important consumers.

Note

- i. **S.E GSO Circle FESCO advised to instruct concerned formation may be sure neither no area affect nor load shedding involved during above shut downs.**
- ii. XEN SS&T Divisions under GSO Circle FESCO Faisalabad will adopt all safety measures and shutdowns may be allowed / availed only when the same is approved from Director RCC North Islamabad / Director RCC South Jamshoro & update on PITC / FESCO Web sites.
- iii. The approval will stand cancelled if a prior unforeseen long duration outage occurs in the system.
- iv. A copy of office order will be given to Dy; Director DCC FESCO for update on PITC Web Site and FESCO Computer Center for update on FESCO Web Site.

This issue with the approval of competent Authority.

S/D

**Dy: Director (Dev) T&G
FESCO H/Q Faisalabad**

- G.M (Opr) FESCO Faisalabad.
- C.E (O) FESCO Faisalabad / DM (O) FESCO Faisalabad for information.
- Director RCC South Jamshoro / Director RCC North Islamabad for further approval.
- All XEN SS&T Divisions under GSO Circle FESCO Faisalabad for information.
- Director RCC North Islamabad / Director RCC South Jamshoro for further approval.
- Dy: Director (DCC) FESCO Faisalabad for information and further necessary action.
- FESCO Information Center Regional Office Faisalabad-118.
- Dy Director (NW) FESCO Computer Centre for publicity through FESCO web site.
- SO to Chief Executive Officer FESCO.