

## **INVITATION FOR BID**

Faisalabad Electric Supply Company Limited (FESCO) invites sealed bids from WAPDA/PEPCO/DISCO's approved manufacturers/suppliers duly pre-qualified/registered with PEPCO/NTDC/DISCOs in required categories for the supply of material mentioned against each according to WAPDA/PEPCO/NTDC specifications (amended to date) and also registered with Income Tax and Sales Tax Departments. The validity of bids is **80-Days** and for free delivery at consignee's store (FCS) Central Store Warehouse FESCO Nishatabad, Faisalabad basis exclusive of General Sales Tax and without involving foreign exchange.

<b>TENDER NO.NCB-592/FESCO/PMU/GSC/2023-24</b>			
Time & Date of Receiving of Tender	11:00 AM 29/02/2024	Time & Date of opening of Tender	11:30 AM 29/02/2024
<b>Evaluation Criteria:</b>	<b>Tender will be evaluated "On LOT Wise Basis"</b>		
Sr. No.	Item Description	Unit	Qty
<b>LOT-I</b>			
1	145KV, 40KA, 2000 Amp, 110V DC 3-pole SF-6 Gas Circuit Breaker (extended creepage) with Steel Supporting Structure, grouting bolts and terminal connectors as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	14
<b>LOT-II</b>			
1	145KV, 40KA, 2000 Amp, 110V DC 3-pole SF-6 Gas Circuit Breaker (extended creepage) with Steel Supporting Structure, grouting bolts and terminal connectors as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	12
<b>LOT-III</b>			
1	145KV, 40KA, 2000 Amp, 110V DC 3-pole SF-6 Gas Circuit Breaker (extended creepage) with Steel Supporting Structure, grouting bolts and terminal connectors as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	10
<b>TENDER NO.NCB-593/FESCO/PMU/GSO&amp;DW/2023-24</b>			
Time & Date of Receiving of Tender	11:00 AM 29/02/2024	Time & Date of opening of Tender	11:45 AM 29/02/2024
<b>Evaluation Criteria:</b>	<b>Tender will be evaluated "On LOT Wise Basis"</b>		
Sr. No.	Item Description	Unit	Qty
<b>LOT-I/(GSO)</b>			
1	145KV, 40KA, 2000 Amp, 110V DC 3-pole SF-6 Gas Circuit Breaker (extended creepage) with Steel Supporting Structure, grouting bolts and terminal connectors as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	04
<b>LOT-II/(DW)</b>			
1	145KV, 40KA, 2000 Amp, 110V DC 3-pole SF-6 Gas Circuit Breaker (extended creepage) with Steel Supporting Structure, grouting bolts and terminal connectors as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	05

<b>TENDER NO.NCB-594/FESCO/PMU/GSC&amp;(DEPOSIT-WORK)/2023-24</b>			
Time & Date of Receiving of Tender	11:00 AM 29/02/2024	Time & Date of opening of Tender	12:00 Noon 29/02/2024
<b>Evaluation Criteria:</b>	<b><u>Tender will be evaluated "On LOT Wise Basis"</u></b>		
<b>Sr. No.</b>	<b>Item Description</b>	<b>Unit</b>	<b>Qty</b>
<b><u>LOT-I/(GSC)</u></b>			
1	132KV Transformer C.Ts 100:200/5-5-5 Amp along with Steel Supporting Structure, Terminal Clamps & grouting bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	20
<b><u>LOT-II/(GSC)</u></b>			
1	132KV Transformer C.Ts 100:200/5-5-5 Amp along with Steel Supporting Structure, Terminal Clamps & grouting bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	19
<b><u>LOT-III/(DW)</u></b>			
1	132KV Transformer C.Ts 100:200/5-5-5 Amp along with Steel Supporting Structure, Terminal Clamps & grouting bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	03
<b>TENDER NO.NCB-595/FESCO/PMU/GSC&amp;(DEPOSIT-WORK)/2023-24</b>			
Time & Date of Receiving of Tender	11:00 AM 29/02/2024	Time & Date of opening of Tender	12:15 PM 29/02/2024
<b>Evaluation Criteria:</b>	<b><u>LOT-I will be evaluated "On Item Wise Basis"</u></b>		
<b>Sr. No.</b>	<b>Item Description</b>	<b>Unit</b>	<b>Qty</b>
<b><u>LOT-I/(DW)</u></b>			
1	132kV, 40kA, Single Phase Metering C.Ts Ratio 1200:600:300/1 Amp, Accuracy Class 0.2-S along with Steel Supporting Structures, Terminal Clamps & Grouting Bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	06
2	132kV Voltage Transformers (Grid Metering) Accuracy Class 0.2, Ratio 132kV/ $\sqrt{3}$ /110/ $\sqrt{3}$ Single Phase Single Core with extended creepage distance along with Steel Supporting Structures, Terminal Clamps & Grouting Bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	06
3	145 KV Current Transformer 800:400/1 Amp along with Steel Supporting Structures, Terminal Clamps & Grouting Bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	No.	03
4	11KV Neutral C.T 50/5 Amp	No.	01
<b><u>LOT-II/(GSC)</u></b>			
1	145 KV Current Transformer 800:400/1 Amp along with Steel Supporting Structures, Terminal Clamps & Grouting Bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	No.	03

<b>TENDER NO.NCB-596/FESCO/PMU/GSC&amp;GSO&amp;DW/2023-24</b>			
Time & Date of Receiving of Tender	11:00 AM 29/02/2024	Time & Date of opening of Tender	12:30 PM 29/02/2024
<b>Evaluation Criteria:</b>	<b>Tender will be evaluated "LOT Wise Basis"</b>		
<b>Sr. No.</b>	<b>Item Description</b>	<b>Unit</b>	<b>Qty</b>
<b>LOT-I/(GSC)</b>			
1	11KV Incoming Panel 25KA 2500 Amp for 40MVA Power Transformers as per WAPDA/PEPCO/NTDC Specification No.P-44:96	Nos.	04
2	11KV Incoming Panel 25KA 2500-Amp for 20/26 MVA Power Transformers as per WAPDA/PEPCO/NTDC Specification No.P-44:96	Nos.	10
3	11KV Capacitor Control Panel as per WAPDA/PEPCO/NTDC Specification No.P-44:96	Nos.	05
4	11KV Bus Coupler 25KA 2500Amp as per WAPDA/PEPCO/NTDC Specification No.P-44:96	Nos.	06
<b>LOT-II/(GSO)</b>			
1	11KV Incoming Panel 25KA 2500-Amp for 20/26 MVA Power Transformers as per WAPDA/PEPCO/NTDC Specification No.P-44:96	Nos.	02
2	11KV Capacitor Control Panel as per WAPDA/PEPCO/NTDC Specification No.P-44:96	Nos.	03
<b>LOT-IV/(DW)</b>			
1	11KV Incoming Panel 25KA, 2500 Amp for 40MVA Power Transformers as per WAPDA/PEPCO/NTDC Specification No.P-44:96	Nos.	01
2	11KV, 25KA, 630Amp Outgoing Panels as per WAPDA/PEPCO/NTDC Specification No.P-44:96	Nos.	08
3	11KV Capacitor Control Panel as per WAPDA/PEPCO/NTDC Specification No.P-44:96	Nos.	01

1. **National Competitive Bidding (NCB)** will be conducted in accordance with Single Stage, One-Envelope procedure and is open to all eligible bidders.
2. Eligible Bidders may obtain further information regarding the Bidding Documents from the Office of undersigned.
3. Interested Bidders may obtain bidding documents containing all necessary information from the address given below from in office working hours (Monday to Friday).
4. The bidder must have at least five (5) years manufacturing or supplying experience of similar equipment with the same or higher rating and capacity and last three (3) years or beyond successful continuous operational experience.
5. Bidder/Tenderer will submit a certificate at the time of purchase of bidding document that the firm is not black listed/debarred from WAPDA/DISCO's/GENCO's/NTDC/PEPCO or any International Organization at present.

6. The Authorization Letter of the Manufacturer in the name of firm/supplier is required for issuance of tender / bidding documents as well as Authority Letter of firm's representative is also required with copy of CNIC.

7. The Bidding Document, in English language may be purchased by the interested bidders from the date of publishing and on the submission of a written application to the address below upto one day prior to opening date during office hours on the production of prequalification/registration and sales tax registration number/other documents/proof. Cost of each tender form is **Rs.2000/-** (Non refundable) per document. **No tender document will be issued on the tender opening date.**

8. The bids be prepared in accordance with the instructions in the bidding documents must reach the Office of Chief Engineer (Development) PMU Old Thermal Plant FESCO Abdullahpur FESCO Faisalabad on or before tender opening date and receiving time mentioned against each tender.

9. Earnest/bid money @ 02 % for registered firms of the quoted price in shape of Call Deposit Receipt, Bid guarantee issued by any scheduled Bank of Pakistan or WAPDA bearer bonds valid for **28-days** beyond the bid validity of tender in favour of Chief Executive Officer FESCO, Faisalabad must accompany with the bid, otherwise bid will be rejected.

10. All the procurement will be done according to PPRA Rules 2004.

11. The advertisement is also available on FESCO ([www.fesco.com.pk](http://www.fesco.com.pk)) and PPRA ([www.ppra.org.pk](http://www.ppra.org.pk)) websites.

**NOTE: FESCO reserves all its rights regarding rejection of tenders without providing any justification as defined in clause 33 (1) of PPRA Rules 2004.**

Chief Engineer (Development)  
PMU FESCO Faisalabad  
Tel: 041-9220397 Fax: 041-9220691  
E-mail: [directorprofesco@gmail.com](mailto:directorprofesco@gmail.com)  
[cedevfesco@yahoo.com](mailto:cedevfesco@yahoo.com)

**CC:-**

1. General Manager (Operation) FESCO Faisalabad for information please.
2. Master File.